



## Annual Survey

Office: **Aberdeen**

Date: **16 December 2016**

This Certificate is issued to Bluemanta International Ltd, Purchase Order No. 25133 to verify that the undersigned Surveyor attended the premises of ALS Wellvention, Unit 1 West Park Drive Blackburn ,Aberdeen AB21 0BU on 16 December 2016 for the purpose of carrying out a survey on the undernoted equipment.

**Description** 1 off Offshore Container c/w Heater, Electric Lighting and Controls – Zone 2, 3G IIB T3

**Serial Number** BM-C-1403

**Now Done** A close and visual inspection, to EN 60079-17 was carried out on the electrical equipment fitted to the unit and all were found acceptable.

The unit was functionally tested and operated correctly. .

Visual inspection of the sling set, frame and shackle's with no damage or deterioration noted

Universal Inspections Ltd certification 134927/200 dated 28 October 2016 reviewed.

Sulzer Electrical Report Ref M121081 dated 03 February 2016 was satisfactorily reviewed.

Previous DNV certificate N14105UGA dated 28 January 2015 was satisfactorily reviewed.

The Unit must be securely earthed before use

On the basis of the activities now described, it is considered that the above Unit tested under survey satisfies the requirements of the above mentioned purchase order and the criteria for operation within a Zone 2 Hazardous Area on offshore installations as defined in BS EN 60079-10-1: 2009

Group II Category 3 G IIB Temperature Class T3 as Declared by Manufacturer.

Installation offshore in UK sector and subsequent testing to be verified to the requirements of the Duty Holder's Verification Scheme. This report may contribute to a Duty Holder's Verification Scheme if examined by the appointed ICP and considered to meet the Scheme requirements.



David Jarvie  
Surveyor to Lloyd's Register EMEA

a member of the Lloyd's Register group.